Sweetwater Union High School District - Failed Fire Alarm Inspections
NFPA Testing Results Report

Service Organization: Time & Alarm Systems, 3828 Wacker Drive, Mira Loma, CA 91752

KEY:

ANSUL- Ansul; **HD**- Heat Detector; **ADM**- Relay Module; **DD**-Duct Detector; **CM**- Control Module; **SD**- Smoke Detector; **WF**- Waterflow

FACP- Fire Alarm Control Panel; **MM**- Monitor Module; **SS**- Supervisor Switch; **SNAC**- Power Supply; **PS**- Pull Station; **TS**- Tamper Switch;

Name of School	Date	Equip. Deficiencies	Non-Working Alarms	Non-Working Strobes	Problems: Device/ Unit Location
1. Bonita Vista Middle School 650 Otay Lakes Rd, Chula Vista, CA 91910	6/20/2013	12	11	1	BLD 300; 500; Outside H2, 704, 706; Interior horns: H1, H2, H3
2. Bonita Vista High School 751 Otay Lakes Road, Chula Vista, CA 91913	3/20/2013	34	23	1	Sub Loop Theater heats; Gym Lobby; Heat Detectors blown or not working
3. Castle Park High School 1395 Hilltop Drive Chula Vista, CA 91911	5/17/2013	20	15	1	Boys/ Girls Locker rooms- no sound; Pull Arms- missing or hanging wires,
4. Castle Park Middle School 160 Quintard Street, Chula Vista, CA 91911	5/23/2013	More than 13	13	All [Admin/500 BLD]	BLD 800- portable restroom, interior strobes & exterior horns- all not working
5. Chula Vista Adult School 1034 Fourth Avenue, Chula Vista, CA 91911	6/25/2013	8	8	0	Only HD's located B100 are connected to fire alarm system.
6. Chula Vista High School 820 Fourth Ave., Chula Vista, CA 91911	3/26/2013	38	20	13	ADMIN BLD pulls frozen; Portable classrooms- no sirens or not working
7. Chula Vista Middle School 415 Fifth Ave., Chula Vista,CA. 91910	3/11/2013	17	11	6	No HD's in zone E3; ADMIN - no horns; Boys RR 317- no strobe; PRINC. SD hanging
8. Eastlake High School 1120 Eastlake Parkway Chula Vista, CA 91915	6/6/2013	23	14	6	RM 603, 404, 405, 406, 1602, 1605 FCID panels/FCI E3 - connection problem
9. Eastlake Middle School 900 Duncan Ranch Road, Chula Vista, CA 91914	6/17/2013	32	25	5	RM 716, 802, 805, 415 -all horns 600 BLDG not working- but strobes ok
10. Granger Middle School 2101 Granger Avenue, National City, CA 91950	6/17/2013	5	5	0	Heat detectors in many locations do not have an alarms/ All no labels
11. Hilltop High School 555 Claire Avenue Chula Vista, CA 91910	3/28/2013	20	12	0	SD's and exterior manual stations on BLD 900 - no alarms
12. Hilltop Middle School 44 East J Street, Chula Vista, CA 91910	4/9/2013	13	4	0	Supervisor switch missing, Duct Detector programmed as SD.
13. Mar Vista High School 505 Elm Avenue Imperial Beach, CA 91932	2/4/2013	23	8	0	1500 Vistor Girls RR- No alarm
14. Mar Vista Middle School 1267 Thermal Avenue, San Diego, CA 92154	4/12/2013	19	12	0	BLDG 500, 700, 900, Boys locker room, Girls Locker Room, Library- NO ALARMS

Sweetwater Union High School District - Failed Fire Alarm Inspections

NFPA Testing Results Report

Sweetwater Union High School District - Failed Fire Alarm Inspections
NFPA Testing Results Report

15. Montgomery Adult School 3240 Palm Avenue, San Diego, CA 92154	4/19/2013				No Deficiencies Reported
16. Montgomery High School 3250 Palm Avenue San Diego, CA 92154	4/19/2013	20	15	Strobes out of sync	RMS 01-808 No Alarms, RM 809-811 1000 Portable HD's- No alarms
17. Montgomery Middle School 1051 Picador Blvd, San Diego, CA 92154	5/7/2013	7	4	0	900 BLDG HD's, Boy's locker room, PE BLD, Girl's Locker room,
18. National City Adult School 517 Mile of Cars Way National City, CA 91950	6/26/2013				No broken alarms reported
19. National City Middle School 1701 D Avenue, National City, CA 91950	6/26/2013	11	5		ADMIN BLD, 500, 400, 1600 BLD, 900 BLD ALL - No alarms
20. Olympian High School 1925 Magdalena Avenue Chula Vista, CA 91913	5/20/2013				All Alarms OK
21. Otay Ranch High School 1250 Olympic Parkway Chula Vista, CA 91913	4/29/2013	25	12	8	SD's- BLD 200, 1544 ELEC RM, 1510 WGT RM RM 1504 A&B, 1508B- no alarms
22. Palomar High School 480 Palomar Street Chula Vista, CA 91911	6/21/2013	8	8	0	Smoke detector L2M01 – no alarm
23. Rancho Del Rey Middle School 1174 East J Street, Chula Vista, CA 91910	3/18/2013	52	38	2	25 devices have no alarm when tested
24. San Ysidro Adult School 4220 Otay Mesa Road, San Ysidro, CA 92173	6/27/2013				No Deficiencies Reported.
25. San Ysidro High School 5353 Airway Road San Diego, CA 92154	5/29/2013	48	20	20	SD-GYM 1 508B, RELO 4 South, ROOM 8302 No alarms
26. Southwest High School 1685 Hollister Street San Diego, CA 92154	6/25/2013	14	3	3	DD- M1 23, M1 24, M1 25 - Failed
27. Southwest Middle School 2710 Iris Ave San Diego, CA 92154	6/24/2013	5	2	0	SD 3 (Address L1S024); RELO 12- Not installed SD Auditorium - No alarm
28. Sweetwater High School 2900 Highland Avenue, National City, CA 91950	4/30/2013	18	11	1	BLDG 500, 700, 800, 900, Cafeteria, Girls Locker room, Restroom BLDG by new welding building, Outside Horn Room 1303 – ALL FIRE ALARMS